

**Adequacy Reserve Margins (ARMs)**

3/5/2015

**2020 Ref Wind**
**4532 MW**
**Capacity - Adequacy Reserve Margin**

Resource Type	ARMc Calculation	Q4	Q1	Q2	Q3
Thermal	Winter Capacity * (1 - FOR) (see note 2)	12427	12427	12427	12427
Wind	5%	227	227	227	227
Hydro	10-hr Sustained Peak (see note 1)	15758	16490	13338	14831
Firm contracts	1-Hour Peak	-225	-167	-493	-631
<b>Total Resource</b>		<b>28187</b>	<b>28977</b>	<b>25499</b>	<b>26854</b>
<b>Load</b>	1-Hour Peak (weather normalized)	28569	29202	24779	25809
L/R Balance	Resource - Load	-382	-225	720	1045
<b>ARMc</b>	<b>(Resource - Load)/Load</b>	<b>-1.3%</b>	<b>-0.8%</b>	<b>2.9%</b>	<b>4.1%</b>
<b>ARMc + IPP</b>		9%	10%	7%	8%
<b>ARMc + IPP + SW</b>		18%	18%	7%	8%

**Energy - Adequacy Reserve Margin**

Resource Type	ARMe Calculation	Q4	Q1	Q2	Q3
Thermal	Winter Capacity * (1 - FOR) * (1 - Maint)	11516	11516	11516	11516
Wind	30%	1360	1360	1360	1360
Hydro	Critical Year Hydro (FELCC)	11827	10642	13794	10569
Firm contracts	Period Average	-325	-200	-729	-802
<b>Total Resource</b>		<b>24377</b>	<b>23317</b>	<b>25940</b>	<b>22642</b>
<b>Load</b>	Peirod Average (weather normalized)	22392	23518	20307	20788
L/R Balance	Resource - Load	1986	-201	5633	1854
<b>ARMe</b>	<b>(Resource - Load)/Load</b>	<b>8.9%</b>	<b>-0.9%</b>	<b>27.7%</b>	<b>8.9%</b>
<b>ARMe + IPP</b>		22.4%	12.0%	32.7%	13.7%
<b>ARMe + IPP + SW</b>		33.5%	22.6%	32.7%	13.7%

**Note:** 1. Hydro sustained peak based on lowest period energy, NOT on FELCC

See Hydro Tab to see sustained peak based on FELCC

2. Resource capacity adjustment to get to 5% LOLP

3. Resource energy adjustment is 90% of capacity

4. The resource adjustment is DRAFT

**300 MW**  
**270**