


# Calculating the Adequacy Reserve Margin (ARM)



SAAC/RAAC Joint Committee Meeting  
Portland, Oregon  
April 17, 2015


# GENESYS vs. RPM

- GENESYS
  - Assesses power supply adequacy for 1 year
  - For a specific resource mix
  - Hourly time step
- RPM
  - Calculates average cost and tail-end cost
  - For various resource plans over 20 years
  - Quarterly time step

# Future Uncertainties Modeled

Uncertainty	GENESYS	RPM
80-Year Hydro	Yes	Yes
Wind variation	Yes, temp correlated	No
Solar variation	No	No
Thermal Forced Outages	Yes	Yes
Temp variation in load	Yes	Yes
Long-term load growth	No	Yes
Fuel prices	No	Yes
Carbon tax	No	Yes
Tax credits	No	Yes
Construction costs	No	Yes
EE costs	No	Yes

# RPM vs. GENESYS Loads<sup>1,2</sup>



# Adequacy Test in RPM

- Council's standard is 5% maximum LOLP
- Difficult to implement dynamic<sup>1</sup> LOLP calculation into RPM
- Need to translate probabilistic LOLP into deterministic metric that can be used dynamically
- LOLP  $\Rightarrow$  Adequacy Reserve Margin

<sup>1</sup>Means calculating LOLP as the RPM steps through study years.

# Adequacy Reserve Margin

- From a GENESYS run that just meets the 5% LOLP standard
- $ARM_E$  (energy) = (quarterly energy – quarterly load)/quarterly load
- $ARM_C$  (capacity) = (peak capacity – 1-hour load)/1-hour load
- **Resources:** rate-based<sup>1</sup> generation capacity and energy
  - Hydro
    - Energy: FELCC (1937 hydro year generation)
    - Capacity: 10-hour sustained peak capacity for lowest monthly hydro generation
  - Wind
    - Energy: 30% of nameplate
    - Capacity: 5% of nameplate
- **Loads:** weather-normalized quarterly and 1-hour-peak loads
- Use winter quarter ARM values for the adequacy test

<sup>1</sup>Means only “firm” resources.

# ARM<sub>C</sub> (Capacity)

Resource Type	Adequacy Reserve Calc	Winter Quarter (Q1)
Thermal	Winter Capacity * (1 – FOR)	12,539
Wind	5% Nameplate	227
Hydro	10-hr Sustained Peak	16,490
Firm contracts	1-Hour Peak	-167
<b>Total Resource</b>		<b>29,089</b>
Load	1-Hour (weather normalized)	29,202
<b>ARM Capacity</b>	<b>(Resource - Load)/Load</b>	<b>-0.4%</b>

# ARM<sub>E</sub> (Energy)

Resource Type	Adequacy Reserve Calc	Winter Quarter (Q1)
Thermal	Winter Cap * (1-FOR) * (1-Maint)	11,608
Wind	30% Nameplate	1360
Hydro	Critical Period (1937)	10,642
Firm contracts	Quarterly Average	-200
<b>Total Resource</b>		<b>23,409</b>
Load	Q Average (weather normalized)	23,518
<b>ARM Energy</b>	<b>(Resource - Load)/Load</b>	<b>-0.5%</b>



# Example of How the $ARM_C$ Works (For 1 year in 1 game)

RPM Resource Need Example	Winter Quarter Value (Q1)
RPM Total Rate-based Critical Resource	28,654
RPM Peak Capacity Load	30,485
Implied RPM Adequacy Reserve	$(28,654 - 30,485) / 30,485 = -6.0\%$
GENESYS ARM Capacity Minimum	-0.4%
<b>Conclusion:</b> RPM ARM too low	RPM resources not adequate
<b>Action:</b> RPM needs more resource	
Resource needed = $(ARM * Load) + Load$	$(-0.004 * 30,485) + 30,485 = 30,363$
Incremental resource need	$30,363 - 28,654 = 1,709 \text{ MW}$