

Appendix F: Model Conservation Standards

Introduction..... 1

The Model Conservation Standards For New Electronically Heated Residential and Commercial Buildings..... 1

New Site Built Electrically Heated Residential Buildings and New Electrically Heated Manufactured Homes..... 2

Utility Conservation Programs for New Residential Buildings..... 3

New Commercial Buildings..... 7

Utility Conservation Programs for New Commercial Buildings..... 8

Buildings Converting to Electric Space Conditioning or Water Heating Systems..... 8

Conservation Programs not Covered by Other Model Construction Standards 9

Surcharge Recommendation 10

Surcharge Methodology..... 10

Identification of Customers Subject to Surcharge 11

Calculation of Surcharge..... 11

Evaluation of Alternatives and Electricity Savings 11

INTRODUCTION

As directed by the Northwest Power Act, the Council has designed model conservation standards to produce all electricity savings that are cost-effective for the region. The standards are also designed to be economically feasible for consumers, taking into account financial assistance from the Bonneville Power Administration and the region’s utilities.

In addition to capturing all cost-effective power savings while maintaining consumer economic feasibility, the Council believes the measures used to achieve the model conservation standards should provide reliable savings to the power system. The Council also believes actions taken to achieve the standards should maintain, and possibly improve upon the occupant amenity levels (e.g., indoor air quality, comfort, window areas, architectural styles, and so forth) found in typical buildings constructed before the first standards were adopted in 1983.

The Council has adopted six model conservation standards. These include the standard for new electrically heated residential buildings, the standard for utility residential conservation programs, the standard for all new commercial buildings, the standard for utility commercial conservation programs, the standard for conversions, and the standard for conservation programs not covered explicitly by the other model conservation standards¹.

THE MODEL CONSERVATION STANDARDS FOR NEW ELECTRONICALLY HEATED RESIDENTIAL AND COMMERCIAL BUILDINGS

The region should acquire all electric energy conservation measure savings from new residential and new commercial buildings that have a benefit-to-cost ratio greater than one when compared

¹ This chapter supersedes the Council's previous model conservation standards and surcharge methodology.

to the Council's forecast of future regional power system cost². The Council believes that at least 85 percent of all regionally cost-effective savings in new residential and commercial buildings are practically achievable. The Council finds that while significant progress has been made toward improving the region's residential and commercial energy codes these revised codes will not capture all regionally cost-effective savings in these sectors. The Council's analysis indicates that further improvements in existing residential and commercial energy codes would be both cost-effective to the regional power system and economically feasible for consumers.

The Council is committed to securing all regionally cost-effective electricity savings from new residential and commercial buildings. The Council believes this task can be accomplished best through a combination of continued enhancements and enforcement of state and local building codes and the development and deployment of effective regional market transformation efforts. Bonneville and the region's utilities should support these actions. The Council has established four model conservation standards affecting new buildings. These standards are set forth below:

New Site Built Electrically Heated Residential Buildings and New Electrically Heated Manufactured Homes

The model conservation standard for new single-family and multifamily electrically heated residential buildings is as follows: New site built electrically heated residential buildings are to be constructed to energy-efficiency levels at least equal to those that would be achieved by using the illustrative component performance paths displayed in Table E-1 for each of the Northwest climate zones³. New electrically heated manufactured homes regulated under the National Manufactured Housing Construction and Safety Standards Act of 1974, 42 USC §5401 et seq. (1983) are to be built to energy-efficiency levels at least equal to those that would be achieved by using the illustrative component performance paths displayed in Table E-2 for each of the Northwest climate zones. The Council finds that measures required to meet these standards are commercially available, reliable and economically feasible for consumers without financial assistance from Bonneville.

It is important to remember that these illustrative paths are provided as benchmarks against which other combinations of strategies and measures can be evaluated. Tradeoffs may be made among the components, as long as the overall efficiency and indoor air quality of the building are at least equivalent to a building containing the measures listed in Tables F-1 and F-2.

² The term "system cost" means an estimate of all direct costs of a measure or resource over its effective life, including, if applicable, the cost of distribution and transmission to the consumer and, among other factors, waste disposal costs, end-of-cycle costs, and fuel costs (including projected increases), and such quantifiable environmental costs and benefits as the Administrator determines, on the basis of a methodology developed by the Council as part of the plan, or in the absence of the plan by the Administrator, are directly attributable to such measure or resource. [Northwest Power Act, §3(4)(B), 94 Stat. 2698-9.]

³ The Council has established climate zones for the region based on the number of heating degree-days as follows: Zone 1: less than 6,000 heating degree days; Zone 2: 6,000-7,499 heating degree days; and Zone 3: over 7,500 heating degree days.

Utility Conservation Programs for New Residential Buildings

The model conservation standard for utility conservation programs for new residential buildings is as follows: Utilities should implement programs that are designed to capture all regionally cost-effective space heating, water heating and appliance energy savings. Efforts to achieve and maintain a goal of 85 percent of regionally cost-effective savings should continue as long as the program remains regionally cost-effective. In evaluating the program's cost-effectiveness, all costs, including utility administrative costs and financial assistance payments, should be taken into account. This standard applies to site-built residences and to residences that are regulated under the National Manufactured Housing Construction and Safety Standards Act of 1974. 42 USC §5401 et seq. (1983).

There are several ways utilities can satisfy the model conservation standard for utility conservation programs for new residential buildings. These are:

1. Support the adoption and/or continued enforcement of an energy code for site-built residential buildings that captures all regionally cost-effective space heating, water heating and appliance energy savings.
2. Support the revision of the National Manufactured Housing Construction and Safety Standards for new manufactured housing so that this standard captures all regionally cost-effective space heating, water heating and appliance energy savings.
3. Implement a conservation program for new electrically heated residential buildings. Such programs may include, but are not limited to, state or local government or utility sponsored market transformation programs (e.g., Energy Star®), financial assistance, codes/utility service standards or fees that achieve all regionally cost-effective savings, or combinations of these and/or other measures to encourage energy-efficient construction of new residential buildings and the installation of energy-efficient water heaters and appliances, or other lost-opportunity conservation resources.

Table F-1: Illustrative Paths for Model Conservation Standard for New Site Built Electrically Heated Residential Buildings

Component	Climate Zone		
	Zone 1	Zone 2	Zone 3
Ceilings			
• Attic	R-49 (U-0.020) ^{a,b}	R-49 (U-0.020) ^{a,b}	R-49 (U-0.020) ^{a,b}
• Vaults	R-38 (U-0.027)	R-38 (U-0.027)	R-38 (U-0.027)
Walls			
• Above Grade ^c	R-21 Advanced (U-0.051)	R-21 Advanced (U-0.051)	R-21 Advanced (U-0.051)
• Below Grade ^d	R-21	R-21	R-21
Floors			
• Crawlspace and Unheated Basements	R-30 (U-0.029)	R-30 (U-0.029)	R-30 (U-0.029)
• Slab-on-grade - Unheated ^e	R-10 Full Under Slab	R-10 Full Under Slab	R-10 Full Under Slab
• Slab-on-grade - Heated	R-10 Full Under Slab w/R-5 Thermal Break	R-10 Full Under Slab w/R-5 Thermal Break	R-10 Full Under Slab w/R-5 Thermal Break
Glazing ^{f,g}	R-3.33 (U-0.30)	R-3.33 (U-0.30)	R-3.33 (U-0.30)
Exterior Doors	R-5 (U-0.19)	R-5 (U-0.19)	R-5 (U-0.19)
Thermal Infiltration Rate ^h	0.35 ach	0.35 ach	0.35 ach
Ventilation and Indoor Air Quality ⁱ	ASHRAE Standard 62.2-2007 with Heat Recovery Ventilation		
Service Water Heater ^j	Energy Factor = 2.2		
Hardwired Lighting	Maximum Lighting Power Density - 0.6 Watts/sq.ft.		
Space Conditioning System	Minimum Heating Season Performance Factor (HSPF) - 9.0		
	Minimum Seasonal Energy Efficiency Rating (SEER) - 14.0		

^a R-values listed in this table are for the insulation only. U-factors listed in the table are for the full assembly of the respective component and are based on the methodology defined in the *Super Good Cents Heat Loss Reference—Volume I: Heat Loss Assumptions and Calculations and Super Good Cents Heat Loss Reference—Volume II—Heat Loss Coefficient Tables*, Bonneville Power Administration (October 1988).

^b Attics in single-family structures in all zones shall be framed using techniques to ensure full insulation depth to the exterior of the wall. Attics in multifamily buildings in all zones shall be insulated to nominal R-38 (U-0.031).

^c All walls are assumed to be built using advanced framing techniques (e.g., studs on 24-inch centers, insulated headers above doors and windows, and so forth) that minimize unnecessary framing materials and reduce thermal short circuits

^d Only the R-value is listed for below-grade wall insulation. The corresponding heat-loss coefficient varies due to differences in local soil conditions and building configuration. Heat-loss coefficients for below-grade insulation should be taken from the Super Good Cents references listed in footnote “a” for the appropriate soil condition and building geometry.

^e Only the R-value is listed for slab-edge insulation. The corresponding heat-loss coefficient varies due to differences in local soil conditions and building configuration. Heat-loss coefficients for slab-edge insulation should be taken from the Super Good Cents references listed in footnote “a” for the appropriate soil condition and building geometry and assuming a thermally broken slab.

^f U-factors for glazing shall be determined, certified and labeled in accordance with the National Fenestration Rating Council (NFRC) Product Certification Program (PCP), as authorized by an independent certification and inspection agency licensed by the NFRC. Compliance shall be based on the Residential Model Size. Product samples used for U-factor determinations shall be production line units or representative of units as purchased by the consumer or contractor.

^g Glazing area is not limited if all building shell components meet reference case maximum U-factors and minimum R-values. Reference case glazing area equal to 15 percent of conditioned floor area shall be used in thermal envelope component tradeoff calculations.

^h Assumed air changes per hour (ach) used for determination of thermal losses due to air leakage without heat recovery ventilation..

ⁱ The dwelling shall have a heat recovery mechanical ventilation system that is sized to comply with the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) Standard 62.2-2007, *Ventilation and Acceptable Indoor Air Quality in Low-rise Residential Buildings*.

^j Water Heater Energy Factor (EF) varies by tank capacity. EF shown is for 50 gallon nominal tank capacity. EF may be adjusted higher or lower based on actual nominal water heater tank capacity.

Table F-2: Illustrative Paths for the Model Conservation Standard for New Electrically Heated Manufactured Homes

Component	Climate Zone		
	Zone 1	Zone 2	Zone 3
Ceilings			
• Attic	R-49 ^a (U-0.023)	R-49 (U-0.023)	R-49 (U-0.023)
• Vaults	R-38 (U-0.030)	R-38 (U-0.030)	R-38 (U-0.030)
Walls			
• Above Grade	R-21 Advanced (U-0.050)	R-21 Advanced (U-0.050)	R-21 Advanced (U-0.050)
Floors			
• Crawlspace	R-33 (U-0.032)	R-33 (U-0.032)	R-33 (U-0.032)
Glazing ^{b,c}	R-3.33 (U-0.30)	R-3.33 (U-0.30)	R-3.33 (U-0.30)
Exterior Doors	R-5 (U-0.19)	R-5 (U-0.19)	R-5 (U-0.19)
Thermal Infiltration Rate ^d	0.35 ach	0.35 ach	0.35 ach
Overall Conductive Heat Loss Rate (Uo)	0.047	0.047	0.047
Ventilation and Air Quality ^e	ASHRAE Standard 62.2-2007		
Service Water Heater ^f	Energy Factor = 2.2		
Hardwired Lighting	Maximum Lighting Power Density - 0.6 Watts/sq.ft.		
Space Conditioning System	Minimum Heating Season Performance Factor (HSPF) - 9.0		
	Minimum Seasonal Energy Efficiency Rating (SEER) - 14.0		

^a R-values listed in this table are for the insulation only. U-factors listed in the table are for the full assembly of the respective component and are based on the methodology defined in the *Super Good Cents Heat Loss Reference for Manufactured Homes* —

^b U-factors for glazing shall be determined, certified and labeled in accordance with the National Fenestration Rating Council (NFRC) Product Certification Program (PCP), as authorized by an independent certification and inspection agency licensed by the NFRC. Compliance shall be based on the Residential Model Size. Product samples used for U-factor determinations shall be production line units or representative of units as purchased by the consumer or contractor.

^c Glazing area is not limited if all building shell components meet reference case maximum U-factors and minimum R-values. Reference case glazing area equal to 15 percent of conditioned floor area shall be used in thermal envelope component tradeoff calculations.

^d Assumed air changes per hour (ach) used for determination of thermal losses due to air leakage.

^e The dwelling shall have a heat recovery mechanical ventilation system that is sized to comply with the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) Standard 62.2-2007, *Ventilation and Acceptable Indoor Air Quality in Low-rise Residential Buildings*.

^f Water Heater Energy Factor (EF) varies by tank capacity. EF shown is for 50 gallon nominal tank capacity. EF may be adjusted higher or lower based on actual nominal water heater tank capacity.

New Commercial Buildings

The American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. Standard 90.1 (ASHRAE Standard 90.1) is the reference standard in the United States for construction of new commercial buildings. ASHRAE Standard 90.1 is under continuous revision. The Council finds that measures required to meet the current version, ASHRAE Standard 90.1-2007, are commercially available, reliable and economically feasible for consumers without financial assistance from Bonneville. The Council also finds that the measures required to meet the ASHRAE Standard 90.1-2007 do not capture all regionally cost-effective savings.

Furthermore, the Council finds that commercial building energy standards adopted by the four states in the region contain many energy efficiency provisions that exceed ASHRAE Standard 90.1 provisions; produce power savings that are cost-effective for the region and are economically feasible for customers. Those state or locally adopted efficiency provisions that are superior to ASHRAE Standard 90.1 should be maintained. In addition, efforts should be made by code setting jurisdictions to adopt the most efficient provisions of ASHRAE Standard 90.1 or existing local codes so long as those provisions satisfy the conditions for model conservation standards set forth in the Regional Act.

Therefore, the model conservation standard for new commercial buildings is as follows: New commercial buildings and existing commercial buildings that undergo major remodels or renovations are to be constructed to capture savings equivalent to those achievable through constructing buildings to the better of 1) the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) Standard 90.1-2007 -- Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA cosponsored; ANSI approved; Continuous Maintenance Standard), I-P Edition and addenda or subsequent revision to ASHRAE Standard 90.1, or 2) the most efficient provisions of existing commercial building energy standards promulgated by the states of Idaho, Montana, Oregon and Washington so long as those provisions reflect geographic and climatic differences within the region, other appropriate considerations, and are designed to produce power savings that are cost-effective for the region

and economically feasible for customers taking into account financial assistance made available from Bonneville.

As with the residential model conservation standard, flexibility is encouraged in designing paths to achieve the commercial model conservation standards. The Council will consult with the Administrator, States, and political subdivisions, customers of the Administrator, and the public to assist in determining which provisions of existing standards are the most efficient, and provide clear code language, are easily enforced and meet the conditions for model conservation standards set forth in the Regional Act.

Utility Conservation Programs for New Commercial Buildings

The model conservation standard for utility conservation programs for new commercial buildings is as follows: Utilities should implement programs that are designed to capture all regionally cost-effective electricity savings in new commercial buildings. Efforts to achieve and maintain a goal of 85 percent of regionally cost-effective savings in new commercial buildings should continue as long as the program remains regionally cost-effective. In evaluating the program's cost-effectiveness all costs, including utility administrative costs and financial assistance payments, should be taken into account.

There are several ways utilities can satisfy the model conservation standard for utility conservation programs for new commercial buildings. These are:

1. Support the adoption and/or continued enforcement of an energy code for new commercial buildings that captures all regionally cost-effective electricity savings.
2. Implement a conservation program that is designed to capture all regionally cost-effective electricity savings in new commercial buildings. Such programs may include, but are not limited to, state or local government or utility marketing programs, financial assistance, codes/utility service standards or fees that capture all the regionally cost-effective savings or combinations of these and/or other measures to encourage energy-efficient construction of new commercial buildings or other lost-opportunity conservation resources.

Buildings Converting to Electric Space Conditioning or Water Heating Systems

The model conservation standard for existing residential and commercial buildings converting to electric space conditioning or water heating systems is as follows: State or local governments or utilities should take actions through codes, service standards, user fees or alternative programs or a combination thereof to achieve electric power savings from such buildings. These savings should be comparable to those that would be achieved if each building converting to electric space conditioning or electric water heating were upgraded to include all regionally cost-effective electric space conditioning and electric water heating conservation measures.

Conservation Programs not Covered by Other Model Construction Standards

This model conservation standard applies to all conservation actions except those covered by the model conservation standard for new electrically heated residential buildings, the standard for utility conservation programs for new residential buildings, the standard for all new commercial buildings, the standard for utility conservation programs for new commercial buildings and the standard for electric space conditioning and electric water heating system conversions. This model conservation standard is as follows: All conservation actions or programs should be implemented in a manner consistent with the long-term goals of the region's electrical power system. In order to achieve this goal, the following objectives should be met:

1. Conservation acquisition programs should be designed to capture all regionally cost-effective conservation savings in a manner that does not create lost-opportunity resources. A lost-opportunity resource is a conservation measure that, due to physical or institutional characteristics, will lose its cost-effectiveness unless actions are taken now to develop it or hold it for future use.
2. Conservation acquisition programs should be designed to take advantage of naturally occurring "windows of opportunity" during which conservation potential can be secured by matching the conservation acquisitions to the schedule of the host facilities. In industrial plants, for example, retrofit activities can match the plant's scheduled downtime or equipment replacement; in the commercial sector, measures can be installed at the time of renovation or remodel.
3. Conservation acquisition programs should be designed to secure all measures in the most cost-efficient manner possible.
4. Conservation acquisitions programs should be targeted at conservation opportunities that are not anticipated to be developed by consumers.
5. Conservation acquisition programs should be designed to ensure that regionally cost-effective levels of efficiency are economically feasible for the consumer.
6. Conservation acquisition programs should be designed so that their benefits are distributed equitably.
7. Conservation acquisition programs should be designed to maintain or enhance environmental quality. Acquisition of conservation measures that result in environmental degradation should be avoided or minimized.
8. Conservation acquisition programs should be designed to enhance the region's ability to refine and improve programs as they evolve.

SURCHARGE RECOMMENDATION

The Council does not recommend that the model conservation standards be subject to surcharge under Section 4(f) (2) of the Act.

The Council expects that Bonneville and the region's utilities will accomplish conservation resource development goals established in this Plan. If Council recommendations on the role of Bonneville are adopted, utility incentives to pursue all cost-effective conservation should improve. Fewer customers would be dependent on Bonneville for load growth and those that are would face wholesale prices that reflect the full marginal cost of meeting load growth. However, while these changes would lessen the rationale for a surcharge, the Council recognizes that they would not eliminate all barriers to utility development of programs to capture all cost-effective conservation.

The Council recognizes that while conservation represents the lowest life cycle cost option for meeting the region's electricity service needs, utilities face real barriers to pursuing its development aggressively. In particular, because of the current economic conditions, some utilities are experiencing significantly slower or negative load growth. Investments in conservation, like any other resource acquisition, will increase utility cost and place additional upward pressure on rates. Furthermore, there is some uncertainty regarding how public utilities will respond to Bonneville's implementation of rate designs that will result in at least some portion of their loads exposed to cost of new resources. Bonneville has committed to ensure that the "public system" meet its share of the Sixth Plan's conservation targets. It is working with its customers to put in place programs and rate structures that designed to achieve this objective. However, should an individual utility fail to meet its share of the regional conservation goal, then Bonneville may need the ability to recover the cost of securing those savings. In this instance the Council may wish to recommend that the Administrator be granted the authority to place a surcharge on that customer's rates to recover those costs.

The Council intends to continue to track regional progress toward the Plan's conservation goals and will review this recommendation, should accomplishment of these goals appear to be in jeopardy.

Surcharge Methodology

Section 4(f)(2) of the Northwest Power Act provides for Council recommendation of a 10-percent to 50-percent surcharge on Bonneville customers for those portions of their regional loads that are within states or political subdivisions that have not, or on customers who have not, implemented conservation measures that achieve savings of electricity comparable to those that would be obtained under the model conservation standards. The purpose of the surcharge is twofold: 1) to recover costs imposed on the region's electric system by failure to adopt the model conservation standards or achieve equivalent electricity savings; and 2) to provide a strong incentive to utilities and state and local jurisdictions to adopt and enforce the standards or comparable alternatives. The surcharge mechanism in the Act was intended to ensure that Bonneville's utility customers were not shielded from paying the full marginal cost of meeting load growth. As stated above, the Council does not recommend that the Administrator invoke the surcharge provisions of the Act at this time. However, the Act requires that the Council's plan set forth a methodology for surcharge calculation for Bonneville's administrator to follow.

Should the Council alter its current recommendation to authorize the Bonneville administrator to impose surcharges, the method for calculation is set out below.

Identification of Customers Subject to Surcharge

The administrator should identify those customers, states or political subdivisions that have failed to comply with the model conservation standards for utility residential and commercial conservation programs.

Calculation of Surcharge

The annual surcharge for non-complying customers or customers in non-complying jurisdictions is to be calculated by the Bonneville administrator as follows:

1. If the customer is purchasing firm power from Bonneville under a power sales contract and is not exchanging under a residential purchase and sales agreement, the surcharge is 10 percent of the cost to the customer of all firm power purchased from Bonneville under the power sales contract for that portion of the customer's load in jurisdictions not implementing the model conservation standards or comparable programs.
2. If the customer is not purchasing firm power from Bonneville under a power sales contract, but is exchanging (or is deemed to be exchanging) under a residential purchase and sales agreement, the surcharge is 10 percent of the cost to the customer of the power purchased (or deemed to be purchased) from Bonneville in the exchange for that portion of the customer's load in jurisdictions not implementing the model conservation standards or comparable programs.

If the customer is purchasing firm power from Bonneville under a power sales contract and also is exchanging (or is deemed to be exchanging) under a residential purchase and sales agreement, the surcharge is: a) 10 percent of the cost to the customer of firm power purchased under the power sales contract; plus b) 10 percent of the cost to the customer of power purchased from Bonneville in the exchange (or deemed to be purchased) multiplied by the fraction of the utility's exchange load originally served by the utility's own resources⁴.

Evaluation of Alternatives and Electricity Savings

A method of determining the estimated electrical energy savings of an alternative conservation plan should be developed in consultation with the Council and included in Bonneville's policy to implement the surcharge.

⁴ This calculation of the surcharge is designed to eliminate the possibility of surcharging a utility twice on the same load. In the calculation, the portion of a utility's exchange resource purchased from Bonneville and already surcharged under the power sales contract is subtracted from the exchange resources before establishing a surcharge on the exchange load.