Final Adequacy Criteria Recommendation for the 9th Power Plan

RAAC Steering Committee March 27, 2025







The Journey

Course Corrections?

The Destination

RAAC Steering Recommendation





The Journey



Evolving Approach to Adequacy





Northwest **Power** and

Conservation Council

Drivers of Change



Loss of Load Probability was a sufficient risk representation

Risk is no longer just a question of frequency, but also duration and magnitude





Adequacy Standard Evaluation Process



Metric Decision-Making Process

- Ask about adequacy goals what do we want to protect against?
 - Excessively high use of emergency measures
 - Long duration shortfalls
 - Big capacity shortfalls
 - Big energy shortfalls

 - N Protect against spending too much on loss of load mitigation

Removed From Consideration

Economic risk based of Value of Lost Load (VoLL).However, VoLL estimations are subjective and tend to be less restrictive. Instead, economic risk determined through Portfolio Expansion Model

User-friendliness

- Easily calculated using adequacy models
- Easily implemented into system expansion models





Metric Consideration

	Option	RA Metric	Big Capacity Shortfall	Big Energy Shortfall	Frequent use of emergency measures	Long shortfall event- duration
	Event-based Metrics	Frequency Duration Magnitude		✓		✓
	Annualized Metrics	LOLEV LOLH (duration) EUE/NEUE			✓	
	Tail-end Metrics	VaR _{97.5} CVaR _{97.5}	✓	✓		✓
-	Hybrid	LOLEV VaR _{97.5} Energy/Peak/ Duration	✓	~	~	~





Redefining Risk Approach

- Adequacy studies simulate the NW power system to meet NW load
- In each simulation, representing one year, a simulated model shortfall event occurs over a time period when load cannot be served by resources in the model
- However, a shortfall in the model **does not** necessitate an actual curtailment
 - Rather, it signals non-modeled emergency measures are necessary to avoid curtailment:
- Adequacy metrics evaluate shortfalls to inform risk of using emergency measures







What are Emergency Measures?

• Within utility control ("Type I")

- High operating cost resources not in utility's active portfolio
- High-priced market purchases over max import limits
- Load buy-back provisions
- Industry backup generators

• Extraordinary measures ("Type II")

- Official's call for conservation
- Reduce less essential public load (e.g., gov't buildings, streetlights, etc.)
- Utility emergency load reduction protocols
- Curtail F&W hydro operations

rvation Counci

Staff engaged with the RAAC on approximating regional aggregate emergency capabilities to inform adequacy framework.

There is no clear line in the sand between magnitude of Type I and Type II measures





Philosophical Approach to Thresholds



Emergency Capabilities

Available emergency capabilities for the region is the main driver for the initial provisional limits



What level of risk is the aggregate emergency capabilities of the region able to protect?

Collaborated with regional utilities and stakeholders to evaluate and determine **precise and appropriate** regional adequacy thresholds.





2029 Adequacy Assessment Criteria



(summer and winter events)

39 out of 40 years, protecting against events that are too big or too long



Recap of Jan 2024

Engagement Process







High Level Feedback – part 1

- Supportive of multi-metric approach that captures frequency, duration, and magnitude
- Provisional limits seem reasonable, but difficult to quantify magnitude
- Risk tolerance (97.5th percentile) is up for discussion
- Consideration of different seasonal thresholds for summer and winter
- Consideration of Value-of-Lost-Load (VOLL) / other financial measures



High Level Feedback – part 2

- Need to understand relationship of metrics to other planning measures
- Influence of WRAP
- Sensitivity/Caution with setting thresholds
 - Influencing decision on right-sizing portfolios
 - Considerations of customer impacts
 - Rate implications
 - Impact of magnitude and duration on customers





Recap of Jan 2024

Threshold Seasonality for Peak and Energy?

- Possible to set one threshold for winter and one for summer
- However, different temporal resolution could change the distribution and therefore the tail-end values
- Currently, not enough data to suggest seasonal peak and energy values:
 - All studies with the resource strategy have mitigated summer shortfalls and reduced winter shortfalls
 - Stakeholders may experience different seasonal challenges \rightarrow can be an on-going conversation

Interim Recommendation: implement seasonal threshold only for LOLEV Reconsider as more guidance is provided.





Overall Interpretation of Feedback: Apply Conservative Assumptions



Frequency (LOLEV)

Protect against frequency of events <u>**at least**</u> in alignment with the WRAP



Duration

Shorter longest duration



Peak

Aggregate peak capability based on <u>at least</u> the emergency resource available (per data)



Energy

Aggregate annual energy based on **longest** allowed duration at the **peak** capability











Course Correction?



Course Correction?



To season or not to season ... that is the question.



Change market reliance limit?





Protecting Against Events Throughout the Year

- Staff recommend reincorporating annual LOLEV into adequacy criteria alongside winter and summer
 - Maintain 0.1 summer and 0.1 winter LOLEV
 - Set annual LOLEV to 0.2
- Significance:
 - Protect against the same level of adequacy from the WRAP perspective of winter and summer
 - Protect / monitor against the risk of frequent shortfalls in spring and fall
 - Risk of shortfalls occurring during spring maintenance or wildfires in shoulder seasons





Seasonal Peak, Energy, and Duration?

- Staff recommend maintaining the Peak, Energy and Duration as annual metrics
 - Seasonal thresholds require different risk assumptions to align with annual risk
 - Different temporal resolution could change the distribution
 - Consider examples from 2029 Adequacy Assessment:

Threshold 8 hours		1,200 MW	9,600 MWh	
Туре	Var_d_EV	Var_p	Var_e	
Annual	20.6	3,076	196,324	
Winter	20.6	3,076	194,223	
Spring	1	34	34	
Summer	2	680	2,393	
Fall	0	0	0	

Higher Data Center

Scenario would still be deemed **inadequate** under seasonal considerations

Threshold	8 hours	1,200 MW	9,600 MWh
Period	Var_d_EV	Var_p	Var_e
Annual	1.5	1,567	4,196
Winter	1	683	1,056
Spring	0	0	0
Summer	1	143	143
Fall	0	0	0

Low EE

Scenario would be deemed **adequate** under seasonal considerations despite being **inadequate annually**





Role of Market Reliance

- Adequacy results are informed by market fundamentals (capability and price) per outside the region market resources with buildout from AURORA
- Council uses a market (import) reliance limit in the winter (2,500 MW) and summer (1,250 MW) to limit market exposure risk

Changing the Market Reliance Limit will influence the Adequacy Signal







Market Reliance

- Staff recommend maintaining the current market reliance limit for the 9th Plan
 - This is an important topic that is often discussed in the Resource Adequacy and System Analysis Advisory Committees
 - Changing the reliance limit would require re-evaluating the adequacy thresholds
 - A separate process would be needed to determine the new market reliance limit
 - The higher the limit the easier it is to achieve regional adequacy, with the tradeoff of increased market exposure risk





の The Destination

RAAC Steering Recommendation?



Adequacy Criteria for 9th Power Plan





Linking Multiple Adequacy Metrics to Adequacy Reserve Margins

- Using LOLP provided a single measure on required pure capacity
 - i.e. how much pure capacity is needed to reach 5% LOLP
- However, with multiple metrics, there are multiple measures that might require different amounts of pure capacity:
 - Required pure capacity to satisfy VaR Peak
 - Required energy to satisfy VaR Energy
 - Required pure capacity/energy to satisfy VaR Duration
 - Required pure capacity/energy LOLEV





Currently Testing Methodology

• Step 1

- Identify individual pure capacity needed to satisfy each metric (or energy for Energy VaR)

• Step 2

- Test lowest pure capacity needed on sample representative study
 - Uncertainty in categorizing unserved load in each period as either caused by a lack of capacity or energy.
 The interaction of both is likely, and therefore a conservative approach is tested first.
- Iterate to the next pure capacity needed until all metrics are satisfied

Step 3

- Derive annual/seasonal/monthly expected load-resource balance
 - Include pure capacity and energy from Step 2 in the annual signal
 - Determine season/monthly signal via expert judgement
 - (art and science in representing annual metrics)

Under development, will be discussed in upcoming SAAC/RAAC





Questions?

- Any concerns with the recommended criteria?
- Additional open questions to address?
- Other?





Thank you!

Dor Hirsh Bar Gai <u>dhirshbargai@nwcouncil.org</u>





Appendix



LOLEV vs LOLE

Recap of Jan 2024





Recap of January 2024 RAAC Summary of Stakeholder Feedback





GOLDILOCKS PRINCIPLE







LOLEV

- 0.1-0.2 is acceptable range
- However:
 - For some, 0.1 is overly conservative (preference for 0.2)
 - For others, 0.1 is not stringent enough (preference for < 0.1)
 - And lastly, some found it just right
- WRAP context*:
 - LOLE of 0.1, but allowed per season (summer and winter)
- National context:
 - Most utilities use LOLE of 0.1

Country or Region	RA Metrics/Criteria
North America [20,21]	
MISO	LOLE ≤ 0.1 days/year
MRO-Manitoba Hydro	LOLE ≤ 0.1 days/year
NPCC-Maritimes	LOLE ≤ 0.1 days/year
NPCC-New England	LOLE ≤ 0.1 days/year
NPCC-New York	LOLE ≤ 0.1 days/year
NPCC-Ontario	LOLE ≤ 0.1 days/year
NPCC-Québec	LOLE ≤ 0.1 days/year
PJM Interconnection	LOLE ≤ 0.1 days/year
SERC-C	LOLE ≤ 0.1 days/year
SERC-E	LOLE ≤ 0.1 days/year
SERC-FP	LOLE ≤ 0.1 days/year
SERC-SE	LOLE ≤ 0.1 days/year
SPP	LOLE ≤ 0.1 days/year
TRE-ERCOT ³	LOLE ≤ 0.1 days/year
WECC-AB	LOLP4 ≤ 0.02%
WECC-BC	LOLP4 ≤ 0.02%
WECC-WPP-US & RMRG [22]	LOLE ≤ 0.1 days/year
WECC-SRSG	LOLP ≤ 0.02%
WECC-CAMX [23]	PRM ≥ 15% Additional local and flexible RA requirement
Hawaii [24]	ERM ≥ 30% (3 islands), 60% (2 islands)

(EPRI) Resource Adequacy for a Decarbonized Future: A Summary of Existing and Proposed Resource Adequacy Metrics

Food for thought: Annual LOLEV of 0.1 is more stringent than seasonal LOLE 0.1

Interim recommendation: seasonal 0.1 LOLEV in summer and winter to be more aligned with WRAP

Reconsider 0.2 if future studies have acceptable duration and magnitude metrics but LOLEV between 0.1-0.2



*See appendix for reminder of difference between LOLE and LOLEV



Duration VaR 97.5

- Some suggest 8-12 hours is reasonable, but:
 - The question of duration was closely raised to timing of shortfall during extreme weather conditions

Country or Region	RA Metrics/Criteria
Europe [18,25]	
Belgium [26]	LOLH ≤ 3 hours/year
	LOLH95 ⁵ ≤ 20 hours/year
France [27]	LOLH ≤ 3 hours/year
Great Britain [28]	LOLH ≤ 3 hours/year
Ireland and Northern Ireland [29]	LOLH ≤ 8 hours/year (Ireland)
	LOLH ≤ 4.9 hours/year (Northern Ireland)
Netherlands [30]	LOLH ≤ 4 hours/year
Poland [31]	LOLH ≤ 3 hours/year
Portugal [27]	LOLH ≤ 5 hours/year
Spain [27,32]	PRM ≥ 10% (Mainland)
	LOLE ≤ 1 day in 10 years (Island grids)

(EPRI) Resource Adequacy for a Decarbonized Future: A Summary of Existing and Proposed Resource Adequacy Metrics

- Desire to understand societal (value-of-lost-load) and incremental system cost for reducing durations
- Some had no duration-specific feedback
- However:
 - If region wants to include value-of-lost-load, additional extensive research is required
 - In Europe, the duration metric is on an expected value (LOLH), mostly for shorter durations
 - Consider life-threateningcomplientions. Donationations.

Reconsider if (1) duration of concern changes, or (2) future studies have acceptable frequency and magnitude metrics but Duration VaR substantially divergent



Peak and Energy VaR 97.5

- Most difficult to currently quantify minimal guidance from feedback
- Consideration of normalizing the metric to percent of system load:
 - Normalized Peak VaR 97.5th (normalized to annual peak load)
 - Normalized Energy VaR 97.5th (normalized to annual total load)
- Closest sibling for energy metric is Normalized Expected Unserved Energy (NEUE)
 - Substantial difference however: expected (average) vs tail-end (high percentile) approach.
- For peak, early industry consideration, but no established application yet
- Examples from some utilities around the world using NEUE
 - Australia 0.002%
 - India 0.05%

What would these values suggest for PNW with average load of 21,000 MW?

21,000 aMW x 8760 hours = 184,960,000 MWh / year

Impact on threshold: if 0.002% = 3,680 MWh annual energy If 0.05% = 91,980 MWh annual energy





Limited Peak Magnitude Feedback

- Estimated ~1,200 MW:
 - From 2001 BPA dry year tools, ~900 aMW of measures could be considered type I emergency measures (excluding DSI, modeled market purchases, and fish operation reductions).
 - Banks Lake emergency capability of 300 MW
- Assuming <u>at least similar measures exist today</u>, confidence in 2,000-3000 MW of provisional range.
- However, without additional quantitative peak magnitude feedback, it may be beneficial to use 1,200 MW as a conservative floor.

Interim recommendation: Peak VaR 97.5 of 1,200 MW & report NVaR
Reconsider if future studies have acceptable duration and frequency metric
but Peak VaR 97.5 between 2,000-3,000 MW

VaR 97.5	NVaR 97.5
MW	(AVG peak load 40,000 MW)
1,200	3.0%
1,500	3.8%
2,000	5.0%
2,500	6.3%
3,000	7.5%



Extrapolating Annual Energy Threshold



0.002% = 3,680 MWh annual energy 0.05% = 91,980 MWh annual energy



NVaR 97.5 Energy?

	Average Annual
VaR 97.5	Energy MWh
MWh	184,960,000
4,000	0.0022%
6,000	0.0033%
8,000	0.0043%
9,600	0.0052%
10,000	0.0054%
12,000	0.0065%



VaR 97.5 of Normalized Peak and Energy Shortfall

Energy

