# Needs Assessment for Changing Hydro Operations Scenario

October 14, 2025

Jennifer Light, Dor Hirsh Bar Gai, & John Ollis



#### **Today's Discussion**

- Sharing out the results from the needs assessment analysis conducted for the Changing Hydro Operations Scenario
  - How is the hydro system responding to the different operations described in the sensitivities?
  - How are the needs changing across the sensitivities?

- Main goals of today:
  - Use these insights to help inform the discussion around hydro operations taking place as part of the Fish and Wildlife Program amendment process
  - Provide a general sense of the size and shape of the needs for new resources, and how staff
     will use this information to help guide resource optimization modeling for the region

#### **Discussion Outline:**


- 1. Reminder of Scenario
- 2. Operational Differences Across Sensitivities
- 3. Reminder of Role of Needs Assessment
- 4. Needs Assessment Results
- 5. Timeline and Next Steps





# Remember: Hydro System Operations is a Key Nexus in the Council's Work

Program based on recommendations, including operational changes to the hydro system for the benefit of fish. In doing so, the program must ensure the region can maintain an adequate, efficient, economical, and reliable power supply.



Overlap in circles is bigger than it appears!

Power plan puts forward a scheme for resources to meet or reduce Bonneville's obligation, including its ability to implement the Council F&W program. This recognizes that there may be changes to operations for fish that require new resources.

### How Will This Scenario Support the Council's Work?

#### What this analysis does:

- Provides information on how different hydro system operations change power system needs
- Provides a piece of information to inform the Council's decision making on:
  - Recommendations into the Fish and Wildlife Program Amendment process
  - New resource recommendations included in the Ninth Power Plan


#### What this analysis does not do:

- Lock the Council into including any specific recommendations in the Fish and Wildlife Program
  - Power system impacts are only one piece of the many factors the Council will consider when deciding on the Fish and Wildlife Program
- Provide all the information needed to inform the Ninth Power Plan

#### Reminder of Four Sensitivities

2020 BiOp "Flex Spill" Operation	Assuming operations based on the 2020 CRSO EIS to represent "current operations" and provide a basis for comparison
2023 RCBA Operation	Given uncertainty around 2026 operations, using RCBA defined operations to represent a "steady spill" option
Recommended MOP Targets	Analyzing specific minimum operating pool elevations and limits and spill operations recommended by some of the states and tribes
Limited Flex Operation	Analyzes power system implications of limiting the hydro system's ability to change daily elevations and outflows











#### **Discussion Outline:**

- 1. Reminder of Scenario
- 2. Operational Differences Across Sensitivities
- 3. Reminder of Role of Needs Assessment
- 4. Needs Assessment Results
- 5. Timeline and Next Steps





#### Council's GENESYS Model

- GENESYS model serves two important purposes in our system modeling:
  - Assess the region's resource adequacy across a range of future conditions
  - Provides insights on hydro system operations
- Key notes about the model:
  - Multi-stage decision making model that co-optimizes energy and reserves while accounting for fuel use, forecast error and system constraints.
  - Seeks to meet all the system requirements for energy, capacity, and ancillary services while also adhering to all the other resource operating constraints, including operations for fish and wildlife, flood control, etc.
- Keep in mind that while the model aims to capture representative operations, balancing operational level detail with planning, the model is tuned for adequacy specifically





#### **GENESYS Modeling Uses These Data Sources**

Council's Fish and Wildlife Program

Biological Opinion (BiOps)

Water Management
Plan

Fish Operations
Plan

Fish Passage Plan

Columbia River Treaty Assured Operating Plan

Resilient Columbia Basin Agreement – Appendix B\*

Detailed Operating Plan

State and Provincial
Energy &
Environmental
Departments

**Project licenses** 

Utility operators






<sup>\*</sup>RSBA Appendix B is used for some studies, not all.

### Underlying Assumptions of Needs Assessment

- The needs assessment is a 2031 study that assesses a range of hydro conditions, loads, and wind profiles, all of which are connected based on the Council's three climate models
- This results in 90 different simulation years

#### **Climate Models**



C 30 Simulation Parings of Hydro, Wind, Solar, and Loads

**G** 30 Simulation Parings of Hydro, Wind, Solar, and Loads

Climate model key: A = CanESM; C = CCSM; G = CNRM

More info: https://www.nwcouncil.org/fs/18943/2024\_10\_2.pdf






#### What's Consistent Across Sensitivities?

- Hydro operations as defined across these data sources are the basis for all modeling, including:
  - Operations as defined in the BiOps
  - Current Canadian River Treaty operations based on Agreement in Principle
  - Requirements for flood control, recreation, transportation, etc.
- These sources define requirements such as flows, operating range and elevation targets, minimum generation requirements, spill, etc.
- Assumed operational requirements for all projects beyond the lower Columbia and lower Snake
- All sensitivities use the same climate model informed hydro conditions



### **Multiple Obligations**




Hydropower




Flood control



Fish passage & protection




Irrigation



Recreation




Municipal & industrial use



Wildlife habitat



Native American cultural resources



Navigation routes



Water quality & temperature

#### What's Changing Across Sensitivities?

- All changes to operations in the scenario are focused on operations at the lower
   Columbia projects and the lower Snake projects
- Changing assumptions are connected to operations for fish and wildlife and are intended to have minimal to no impacts on other users
- These include:
  - Spill regime: There are different assumptions regarding the timing of spill and the amount of spill that change across the different sensitivities
  - Elevations: Setting target pool elevations for a portion of the year and/or otherwise limiting swings in elevation changes
  - Flows: Setting limitations to the daily fluctuations in flows




## Modeling Changes to Lower Columbia and Lower Snake


Sensitivity	Min Elevation	Elevation Target Sof-Constraint	Elevation Target Hard Constraint	Spill	Outflow Ramp	Reserves Allocation
2020 BiOp	2025 Water Management Plan (WMP)			BiOp spill	2025 WMP	Existing
2023 RCBA				RCBA spill	2025 WMP	Existing
New MOP & Spill	2025 WMP	+1 lower Columbia + 0.5 Lower Snake	+1.5 lower Columbia + 1 Lower Snake	RCBA spill with Aug 30 date	2025 WMP	Existing
Limited Flex	2025 WMP			BiOp Spill	2020-2024 avg.	Half

# Modeled Hydro Operations: The Dalles


#### The Dalles: Average Hourly Outflows




#### The Dalles: Hourly Outflows




#### The Dalles: Average Daily Swing




#### The Dalles: Daily Swing in Outflows




### The Dalles Daily Outflow Range Comparison of Limited Flex to 2020-2024 Actuals




#### The Dalles: Average Hourly Spill




#### The Dalles: Spill Portion of Total Outflows






#### The Dalles: Average Hourly Pool Elevations







### The Dalles: Hourly Pool Elevations




# The Dalles: Average Hourly Generation (by month)



# The Dalles: Average Hourly Generation (by hour)




### The Dalles: Hourly Generation




### Modeled Hydro Ops: Lower Granite


#### Lower Granite: Average Hourly Outflows




#### **Lower Granite: Hourly Outflows**




#### Lower Granite: Average Daily Swing




#### Lower Granite: Daily Swing in Outflows




#### Lower Granite: Average Hourly Spill



### Lower Granite: Spill Portion for BiOp






Flows Turbined Flows Spill




Nov

Sep

### Lower Granite: Average Hourly Pool Elevations




#### **Lower Granite: Pool Elevations**







## Lower Granite: Monthly Generation (by month)



## Lower Granite: Hourly Generation (by hour)




#### Lower Granite: Hourly Generation




# Modeled Hydro Ops: Grand Coulee


### **Grand Coulee: Average Hourly Pool Elevations**




#### **Grand Coulee: Hourly Pool Elevations**




#### **Grand Coulee: Average Hourly Outflows**




#### **Grand Coulee: Hourly Outflows**




#### **Grand Coulee: Average Daily Swing**




#### **Grand Coulee: Daily Swing in Outflows**




### **Grand Coulee: Average Hourly Generation** (by month)



### **Grand Coulee: Average Hourly Generation** (by hour)




#### **Grand Coulee: Hourly Generation**




### Modeled Hydro Operations: Dworshak

#### **Dworshak: Average Hourly Pool Elevations**







#### **Dworshak: Hourly Pool Elevations**




#### **Dworshak: Average Hourly Outflows**




#### **Dworshak: Hourly Outflows**



#### **Dworshak: Average Daily Swing**




#### **Dworshak: Daily Swing in Outflows**




#### **Additional Charts**


#### **Average Hourly Hydro System Generation**




#### **Hydro Generation**




#### **Average Thermal Utilization**



#### **Thermal Generation**




#### **Hydro Balancing & Contingency Reserves**





#### **Average Market Dynamics**




### **Water Transit Times**

#### **Water Transit Time Calculations**

- Several recommendations from states and tribes focused on reducing water transit time (WTT)
- WTT are not a modeled output of GENESYS, but rather an auxiliary calculation based on Fish Passage Center work that uses GENESYS modeled outputs of elevation, storage, and outflows from the sensitivities
- Staff is working closely with the Fish Passage Center to ensure that we are applying their work appropriately



## Implied WTT from Lower Granite to Bonneville Based on GENESYS Modeling




Spring 8 day Recommendation; Summer 13 day Recommendation





## Implied WTT from Wells to Bonneville Based on GENESYS Modleing




**Spring** 8 day Recommendation; **Summer** 13 day Recommendation





## Implied WTT for Mid-C Reach Based on GENESYS Modeling




**Summer** 5 day Recommendation






# Implied WTT for Lower Snake Based on GENESYS Modeling



## Implied WTT for Lower Columbia (after McNary) Based on GENESYS Modeling




**Summer** 8 day Recommendation





## Implied WTT for Lower Columbia (including McNary) Based on GENESYS Modeling




**Summer** 8 day Recommendation






### Implied WTT for Lower Eight Projects Comparison to Actuals (2020-2024)



# Implied WTT of Operating John Day at 257 ft in Spring and Summer

- Some recommenders also requested the Council analyze modeling John Day at 257' as part of the MOP sensitivity
  - This elevation is considered spillway crest and is above minimum operating pools
  - This was outside the scope of the GENESYS analysis for this scenario, but staff were able to estimate an implied WTT assuming this operation
- Holding John Day elevations at 257 ft throughout the spring and summer suggests a ~15% faster WTT between John Day and the Dalles, roughly 0.8-1.4 days shorter.
  - Assuming identical outflow outputs

Season	New MOP	JDA 257*	% Reduction	Day Difference
Spring	4.676	3.997	15%	0.680
Summer	9.201	7.841	14.8%	1.360






#### **Discussion Outline:**

- 1. Reminder of Scenario
- 2. Operational Differences Across Sensitivities
- 3. Reminder of Role of Needs Assessment
- 4. Needs Assessment Results
- 5. Timeline and Next Steps





## **Power Plan Elements and Analytical Flow**



## Reminder on Scenario Modeling

Aurora

Market
Availability
Study

Conduct a study for each sensitivity where **new**resource and transmission options change.

**Changing Hydro Operations Scenario** 

**GENESYS** 

Regional Needs Assessment

Conduct a study for each sensitivity where **existing system** operations change.

OptGen/SDDP

Regional Resource Optimization

Conduct a study for **every** sensitivity.


**GENESYS** 

Strategy Adequacy Check

Conduct a study for every sensitivity & final recommended strategy.


## Super Simplified Description of the Power Plan Needs Assessment


- Step 1: Defining existing system capability (resources in the ground or under construction)
  - This may change over time due to owner announced retirements or conversions, policies, changes to river operations, etc.
- Step 2: Forecasting future electricity demand
- Step 3: Understanding the gap between the existing system and future load growth
- **Step 4:** Translating this into an adequacy reserve margin to inform next phase




### Adequacy Assessment vs Needs Assessment

Adequacy Assessment asks:
"Is the region adequate in a future year **WITH** the Plan Strategy?"





## **Interpreting Needs**





## **Adequacy Criteria for Ninth Power Plan**

Protection against frequent deficits

Protection against extreme (tail-end) deficits



#### Frequency (LOLEV)

0.1 in summer0.1 in winter0.2 annual

Limit to 1 in 10 years summer and winter events, Limit to 1 in 5 years overall



**Duration** 

8-hour



Peak

1,200 MW



#### **Energy**

9,600 MWh

39 out of 40 years, protecting against events that are too big or too long



## Reminder of Existing System

- Existing system assumes all the existing resources, including those under construction today and their capabilities
  - Any owner announced unit conversions are accounted for


- Two caveats to this for this scenario are:
  - Hydro operations: These are varied in each sensitivity as described earlier
  - Transmission: This assumes the "Transmission Plus" view of transmission, which includes four projects that align with the WestTEC 10-year study




### **Reminder of Load Forecast**

 Needs assessment assumes the 2031 load forecasts from the "Mixed Bag" pathway

Pathways	Economics	Transportation	Data Centers	Building Electrification	Hydrogen
Persistent high growth	Medium	Higher	Higher	Higher	Higher
Persistent low growth	Lower	Lower	Lower	Lower	Lower
Early growth	Medium	Lower	Higher	Lower	Lower
Late growth	Medium	Higher	Medium	Higher	Higher
Mixed bag	Medium	Higher	Medium	Lower	Lower










#### **Before We Get to the Results**

 Reminder: This is a needs assessment with the purpose being to define the gap between the existing system and future load growth



In other words, we will see needs, and that is point



#### **Discussion Outline:**

- 1. Reminder of Scenario
- 2. Operational Differences Across Sensitivities
- 3. Reminder of Role of Needs Assessment
- 4. Needs Assessment Results
- 5. Timeline and Next Steps





## **Key Takeaways on Needs**

- The modeling shows significant needs for the region in 2031
- Needs are seen across all seasons, but the largest and longest gaps appear in the winter
- The expected load growth is the largest driver of the needs seen in this study
- There are differences between the sensitivities in terms of needs, with some of the operations showing greater needs than others
  - Note: These differences are not necessarily intuitive, meaning some operations that might be more tuned towards supporting fish mitigation do not necessarily show greater needs
  - Reminder: The Power Act was set up to first do the F&W Program, which might result in derating the hydro system to mitigate for fish, which then allows the Council to identify resource solution that support those and other Bonneville obligations; all while maintaining an adequate, efficient, economical, and reliable power supply
- Peak challenges are greater than energy challenges, meaning that a portfolio of resources will be needed to meet both peak and energy needs identified in these studies throughout the year






## **Frequency of Modeled Events**

- There are a significant number of events across the different sensitivities
- These are seen across all the seasons, with the most in summer

Season	Me	Results	
	Criteria	Allowed # of Events in 90 different simulation years	# of Events in 90 different simulation years
Annual	1 in 5 years	18	15,132 – 19,595
Winter	1 in 10 years	9	4,446 – 6,195
Summer	1 in 10 years	9	4,776 – 7,628





## **Example Simulated Event Record**




### **Most Events are Short and Small**

In each sensitivity, 90% of these are 1 hour and ~93% are less than 1250 MW







## Peak Challenges are Seen Across the Year



# Energy Challenges are Greatest in the Winter, but also Seen in the Summer






## **Overall Results Compared to Metrics**


	Frequency			Extreme Deficits		
	Annual LOLEV (events)	Winter LOLEV (events)	Summer LOLEV (events)	VaR Duration (hr)	VaR Peak (MW)	VaR Energy (MWh)
Adequacy Criteria	0.2	0.1	0.1	8	1,200	9,600
BiOp	218	61	75	22	9,681	354,192
RCBA	210	57	85	21	10,366	348,771
New MOP	189	59	55	21	8,917	326,858
Limited Flex	168	49	53	22	10,200	327,008




### **Peak Needs Across the Sensitivities**



#### **Peak Needs Across the Sensitivities**



## **Energy Needs Across the Sensitivities**



#### **Initial Conclusions**

- The modeling shows significant needs across all seasons, with the largest and longest gaps appear in the winter
- The expected load growth is the largest driver of the needs seen in this study
- There are differences between the sensitivities in terms of needs, and these differences vary by month
- Peak challenges are greater than energy challenges, meaning that a portfolio of resources will be needed to meet both peak and energy needs identified in these studies throughout the year



#### **Discussion Outline:**

- 1. Reminder of Scenario
- 2. Operational Differences Across Sensitivities
- 3. Reminder of Role of Needs Assessment
- 4. Needs Assessment Results
- 5. Timeline and Next Steps





## **Next Steps**

- Continue working on the Changing Hydro Operations Scenario
  - Use the adequacy reserve margins from these needs assessments to guide the OptGen modeling for the resource optimization
- Start modeling for the New Resource and Transmission Risk Scenario
  - Working towards having the market studies for this scenario ready to present to the Council at the November meeting
  - Conducting any additional needs assessments for this scenario where required (e.g. different transmission system looks, different hydro operations if required by F&W program or other information)
  - Use the market studies and appropriate adequacy reserve margins from the existing needs assessments to guide OptGen modeling for resource optimization



## **Further Discussion?**

## **Additional Slides**

## **BiOp Operation**

## **BiOp Operation**

- Staff is using the operations as defined the 2020 Columbia River System
   Operations Environmental Impact Statement to represent "current operations"
  - Legally, with the federal government's withdrawal from the 2023 RCBA and revoking of
     President Biden's Memorandum on Resorting Healthy and Abundant Salmon, Steelhead, and
     Other Native Fish Populations, the operations are assumed to return to the 2020 BiOp
- Between the finalization of the BiOp and the 2023 RCBA defining operations for 2024, there were some shifts in operations moving away from flex spill at most projects to 24-hour spill at some
- For the purposes of this sensitivity, staff assumed operations as defined in the BiOp and not the operations agreed to in years between the BiOp and RCBA



# 2020 BiOp Spill Operations (i.e. Flex Spill)



Project	Spring Operation Lower Snake: 4/3-6/20 Lower Columbia: 4/10-6/15	Summer Operation Lower Snake: 6/21-8/14 Lower Columbia: 6/16-8/14	Summer Operation 8/15-8/31
Lower Granite	16 hr: 125% TDG; 8 hr: 20 kcsf	18 kcsf	RSW or 7 kcsf
Little Goose	16 hr: 125% TDG; 8hr: 30%	30%	ASW or 7 kcsf
Lower Monumental	16 hr: 125% TDG; 8 hr: 30 kcsf	17 kcsf	RSW or 7 kcsf
Ice Harbor	16 hr: 125% TDG; 8 hr: 30%	30%	RSW or 8.5 kcsf
McNary	16 hr: 125% TDG; 8 hr: 48%	57%	20 kcsf
John Day	16 hr: 125% TDG; 8 hr: 32%	35%	20 kcsf
The Dalles	24 hr: 40%	40%	30%
Bonneville	16 hr: 125% TDG; 8 hr: 100 kcfs	95 kcsf	50 kcsf

RSW = removable spillway weir ASW = auxiliary spillway weir





## **RCBA**


## **RCBA Operation**


- While the 2023 RCBA was revoked by President Trump, staff included a sensitivity with these operations to represent a "steady spill" option
- This sensitivity is useful for providing information on how system operations and needs change between a flex spill and steady spill environment
- It's reasonable to assume that if operations ultimately sit somewhere between the BiOp and 2023 RCBA, more akin to operations in 2022 and 2023 for example, that the hydro system and needs impacts would be somewhere in between these two sensitivities
  - Suggesting some tradeoff of increased spill coupled with reduced generation at some projects or months offset by increased generation at others



## **RCBA Operation**

• 2023 Resilient Columbia Basin Agreement included changes to spill operations at several projects, as well as the allocation of reserves at some.









See changes in spring spill, change in summer operations dates, and small changes in late summer spill

## **2023 RCBA Spill Operations**

To compare to the 2020 BiOp spill operations, those are included in the crossed-out text

Remind	er of Four Sensitivities	
2020 BiOp "Flex Spill" Operation	Assuming operations based on the 2018 CRSO EIS to represent "current operations" and provide a basis for comparison	mann Salasana
2023 RCBA Operation	Given uncertainty around 2006 operations, using RCBA defined operations to represent a "steady splif" option	Prince.
Recommended MOP Targets	Analyzing specific minimum operating pool elevations and limits and spill operations recommended by some of the states and tribut.	==
Limited Flex Operation	Analyzes power system implications of limiting the hydro system's shiftly to change deliy elevations and outflows	Tomas I

Project	Spring Operation Lower Snake: 4/3-6/20 Lower Columbia: 4/10-6/15	Summer Operation Lower Snake: 6/21-7/31 <del>8/14</del> Lower Columbia: 6/16-7/31 <del>8/14</del>	Summer Operation <del>8/15</del> 8/1-8/31
Lower Granite	24 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 20 kcsf</del>	18 kcsf	SW flow <del>RSW or 7 kcsf</del>
Little Goose	24 hr: 125% TDG <del>16 hr: 125% TDG; 8hr: 30%</del>	30%	ASW or 7 kcsf
Lower Monumental	24 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 30 kcsf</del>	17 kcsf	SW flow or 8 kcsf <del>RSW or 7 kcsf</del>
Ice Harbor	24 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 30%</del>	30%	SW flow or 9 kcsf <del>RSW or 8.5 kcsf</del>
McNary	24 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 48%</del>	57%	20 kcsf
John Day	16 hr: 40%; 8 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 32%</del>	35%	20 kcsf
The Dalles	24 hr: 40%	40%	30%
Bonneville	24 hr: 125% TDG <del>16 hr: 125% TDG; 8 hr: 100 kcfs</del>	95 kcsf	50 kcsf

## MOP Op

## **MOP Operation**

 This sensitivity was included to analyze specific recommendations around minimum operating pool elevations and target and spill operations as recommended by some of the states and tribes

### Minimum Operating Pool (MOP) Operations

- Operate projects at MOP from March 1 through September 30
- Lower Snake Projects: Hold elevations to 1.0' hard constraint and 0.5' soft constraint
- Lower Columbia Projects: Hold elevations to 1.5' hard constraint and 1.0' soft constraint

#### **Spill Operations**

• Extend summer "performance standard" spill through August 30



### MOP Operations Modeled for Lower Snake Projects

- In the lower Snake there are current MOP operations with a 1.5' hard constraint and a 1.0' soft constraint from April 3 – August 14
- Joint entity recommended operations would tighten these elevations to a 1.0' hard constraint and a 0.5' soft constraint and extend the period to March 1 – September 30

Project	Current Pool Elevation Operations (ft)	MOP Operations Modeled (ft)
Lower Granite	733-734.5	733-734
Little Goose	633-634.5	633-634
Lower Monumental	537-538.5	537-538
Ice Harbor	437-438.5	437-438



### MOP Operations Modeled for Lower Columbia Projects

- There are currently no spill season MOP targets for the lower Columbia projects
- Joint entity recommended operations keep elevations to a 1.5' hard constraint and a 1.0' soft constraint

Project	Current Pool Elevation Operations (ft)	MOP Operations Modeled (ft)
McNary	337-340	337-338.5
John Day	262-266.5	262.5-264
The Dalles	157-160	157-158.5
Bonneville	71.5-76.5	71.5-73





#### **Spill Recommendations**

- As noted above, several entities also included recommendations for spring and summer spill to "achieve the greatest biological benefit while avoiding biological harm" and to achieve powerhouse encounter rates below 1 in support of the 2-6% SAR goal
- Key to these recommendations is that they extend summer spill through August (currently ends on July 31 under RCBA and August 14 under the 2020 BiOp)
- For this sensitivity, staff molded these spill operations, making them additive to what was the spill operation in the RCBA, by modeling 125% TDG for 24 hours a day in the spring and performance standard spill in the summer

#### **Limited Flex**

#### **Limited Flex**


- Sensitivity was intended to provide insight on power system implications of limiting the flexibility of the system
- Reminder:
  - GENESYS model sees more operational flexibility on a daily basis (while meeting all the existing constraints)
     than is currently being utilized in today's actual operations
  - 2021 Power Plan saw value in leaning into this operational flexibility to support the integration of renewables as loads increase
  - At the same time, the Council's 2014 Fish and Wildlife Program contains measures calling on the system to minimize or reduce daily fluctuations and several entities submitted recommendations and comments into this amendment process calling on recommendations to reduce flow fluctuations
- This sensitivity was striving to limit the model's ability to flex to represent operations more akin to current system dynamics of the daily range of outflows of the Lower Snake and Lower Columbia projects



#### **Initial Approach**

- Recognizing the model sees more flexibility than is used in actual operations, staff planned to set flexibility limits based on 2020-2024 changes in elevations and flows
- The initial approach was to take this historical operations and to cut those fluctuations in half
- After initial runs, staff realized it needed to modify the approach somewhat

#### **Reminder from August:**





#### **Updated Approach**


- Rather than trying to get fluctuations to less than where they have been historically based on 2020-2024 actuals, staff updated the target to more closely mimic the daily ranges seen in the historical data
  - A tighter bound on fluctuation was challenging to test in a model at this point in time with no new resource additions; this could be something to test more at a later date if the goal is to indeed reduce daily elevation/outflow changes from where they have been historically
- To mimic these flows, staff incorporated an adjusted average daily range as a new discharge rate limit:

Current	LWG	LGS	LMN	ICH	MCN	JDA	TDA	BON
Water Management Plan allowed discharge								
(kcfs/hour)	70	70	70	20	150	200	150	25
Limited Flex scenario								
(kcfs/hour)	0.96	0.96	0.96	0.96	2.40	2.40	2.40	2.40

### Flow Targets

### McNary Flow Target vs Simulated Outflows


McNary Flow Meeting Objective				
Operation	Spring	Summer		
Actuals	~80% (since 1953)	~ 21% since 1975		
BiOp	64.8%	32.8%		
LimFlex	57.5%	36.7%		
New MOP	67.8%	37.0%		
RCBA	64.9%	27.3%		






### Lower Granite Flow Target vs Simulated Outflows

Lower Granite Flow Meeting Objective				
Operation	Spring	Summer		
Actuals	~61% since 1995	~28% since 1975		
BiOp	49.4%	22.8%		
LimFlex	46.2%	22.5%		
New MOP	46.8%	20.1%		
RCBA	49.0%	23.2%		



# Walkthrough of Significant Deficit in GENESYS


### The same hydro and load conditions drive the worst deficits across sensitivities



Example of largest deficit - in February - under the highest load conditions and average water conditions



### Hydro generation varied across most operations, but is more consistent with Lim Flex




In the days leading up to the deficit, BiOp, RCBA, and New MOP fluctuated their regional hydro generation, whereas Lim Flex did not ramp up and down as much. This may be why the event was smaller in the Lim Flex sensitivity compared to the others





#### Thermal generation followed hydro usage




All operations heavily relied on thermal generation, with LimFlex using less thermal generation the day before





## Low wind conditions across all sensitivities throughout the deficit




Marginal wind generation differences between the operations





#### Market imports capped during event



All operations imported to the market reliance limit (2,500 MW) during the event. The day before some import variability depending on hydro and thermal





## The week before experienced less challenging hydro & wind conditions

