

Henry Lorenzen
Chair
Oregon

Bill Bradbury
Oregon

Guy Norman
Washington

Tom Karier
Washington



Northwest **Power** and **Conservation** Council

W. Bill Booth
Vice Chair
Idaho

James Yost
Idaho

Jennifer Anders
Montana

Tim Baker
Montana

May 9, 2017

MEMORANDUM

TO: Council Members

FROM: John Fazio, Senior Systems Analyst

SUBJECT: Standalone vs. Integrated Capacity Value for Resources

BACKGROUND:

Presenter: John Fazio

Summary: The Council will be briefed on how the inherent storage in the Pacific Northwest's hydropower system can add capacity value to renewable resources, energy efficiency measures and other resources.

Like a traditional battery, a hydropower system can save energy and generate it later. Unlike traditional batteries, however, there are many other constraints on the hydropower system that limit its ability to use its storage. Northwest dams not only provide power but must also be operated to provide flood control, water for irrigation, operations to enhance salmon survival, transportation, and recreation. These constraints limit the usability of hydropower storage differently by season, by month, by day and even by the hour of the day. Nonetheless, the hydropower system still has considerable storage potential that can be used in tandem with non-hydro resources to increase overall system peaking capacity.

Future work is required to further explore how to best integrate a constantly changing mix of resources with the existing hydropower system in order to maximize adequacy, efficiency, economy and reliability.

Relevance: Understanding how non-hydro resources interact with the hydropower's storage system is key to ensuring that future Council resource strategies are efficient and economical. At the same time, knowing the interaction of renewable resources, energy efficiency measures and thermal resources with the hydropower system's operation is absolutely necessary to accurately assessing the adequacy of the region's power supply.

Background: The Council's Seventh Power Plan identified a need to assess the Associated System Capacity Contribution (ASCC) of all non-hydro resources, especially energy efficiency, wind and solar resources. The ASCC indicates the added capacity gained when a particular resource is operated in tandem with the hydropower system. Without the ASCC, the Council's Regional Portfolio Model cannot properly satisfy the adequacy reserve margin (derived from the Council's resource adequacy standard) and, therefore, would not produce resource strategies that ensure adequate supplies.

Briefing on Standalone vs. Integrated Capacity Values

Council Meeting

May 16, 2017

Boise, Idaho

John Fazio, Senior Systems Analyst



Standalone vs. Integrated


- Standalone capacity is the percentage of nameplate capacity that can be counted on to provide adequacy when a resource's generation is applied to the system with no interaction with the hydro system
- Integrated capacity is the percentage of nameplate capacity that can be counted on when allowed to interact with hydro storage



Simple Approach

- Create a peak-hour curtailment probability curve (e.g. sort the peak-hour curtailment for each simulation from highest to lowest)
- Using that curve, estimate how much capacity is needed to lower the probability to a desired value

Peak-Hour Curtailment per Simulation (Sorted by Magnitude)



Capacity Needed for 5% LOLP


■ Blue Columns

- Total number of simulations = 200
- Simulations with curtailment = 18
- $LOLP = 18/200 = 9\%$


■ Red Columns

- Added 500 MW of capacity
- Simulations with curtailment = 10
- $LOLP = 10/200 = 5\%$

Peak-Hour Curtailment Duration Curve (Same as before but LOLP on x-axis)






Start with an Inadequate Base Case



Standalone 930 MW of EE

(no interaction with hydro system)





Annual Capacity Estimate for EE (930MW¹ Energy Efficiency)

Standalone EE Capacity Contribution	Reduction in MW need =	713MW
	Added EE =	930MW
	Standalone Capacity Value	77%
Integrated EE Capacity Contribution	Reduction in MW need =	1184MW
	Added EE =	930MW
	Integrated Capacity Value	127%
Difference between integrated and standalone		50%

¹The 930 MW of EE capacity is the average of expected winter and expected summer peak-hour savings for 600 aMW of annual EE energy savings (winter peak factor is 1.9 and summer is 1.2).

Annual Capacity Estimate for Wind (3,000 MW Gorge Wind)

Standalone Wind Capacity Contribution	Reduction in MW need =	90MW
	Added Wind =	3000MW
	Standalone Capacity Value	3.0%
Integrated Wind Capacity Contribution	Reduction in MW need =	286MW
	Added Wind =	3000MW
	Integrated Capacity Value	9.5%
Difference between integrated and standalone		6.5%

Annual Capacity Value for Solar (3,000 MW Southern Idaho Solar)

Standalone Solar Capacity Contribution	Reduction in MW need =	109MW
	Added Solar =	3000MW
	Standalone Capacity Value	3.6%
Integrated Solar Capacity Contribution	Reduction in MW need =	1157 MW
	Added Solar =	3000 MW
	Integrated Capacity Value	38.6%
	Difference between integrated and standalone	35%

More Precise Method

- Calculate LOLP explicitly, with and without new resource
- Calculate the net system capacity gain
- Integrated capacity value equals net system capacity gain divided by new resource nameplate capacity
- Capacity gain exceeding standalone CV must be attributed to hydro storage
- Can calculate quarterly values


Integrated Capacity Values^{1,2} (AKA Associated System Capacity Contribution)

Resource	Q1	Q2	Q3	Q4
Solar PV	0.26	0.81	0.81	0.42
Energy Efficiency	1.24	1.01	1.14	1.16
Wind	0.03	0.11	0.11	0.08
Gas-Fired Turbine	1.28	1.00	1.02	1.20
Geothermal	1.28	1.00	1.02	1.20

¹The net gain in peaking capability should be attributed to the hydro system.


²Incremental capacity gains diminish as more resource is added.

Standalone vs. Integrated Capacity for Solar



- Some curtailments occur when solar is not generating
- As a standalone resource, surplus solar generation cannot be shifted into other hours

Average Curtailment Standalone and Integrated Solar



Integrated Solar affects both Hydro and Thermal Resources

