Jennifer Anders Chair Montana

> Tim Baker Montana

Guy Norman Washington

Patrick Oshie Washington



Richard Devlin Vice Chair Oregon

> Ted Ferrioli Oregon

> > Jim Yost Idaho

Jeffery C. Allen Idaho

April 30, 2019

MEMORANDUM

- TO: Council Members
- FROM: Steven Simmons
- SUBJECT: Gauging the Potential Impact of Behind-The-Meter Solar + Battery to Modify Load in the Pacific Northwest

BACKGROUND:

- Presenter: Steven Simmons
- Summary: Behind-the-meter solar installations affect the overall system load during the daylight hours while the photovoltaic (PV) systems are generating electricity. As behind-the-meter batteries become available and are paired with PV systems, some of the solar generation could be stored and used later during non-daylight hours. If there were a large build-out of solar + battery systems across the region over the coming decades, the impact on system load, and especially the system load shape and hourly load peaks could be significant.

A study was completed to gauge the potential impact of solar + battery systems on the overall system load and the results were implemented into the long-term load forecast model. The approach was to model the installation of solar + battery systems across the region and aggregate their operations to benefit the grid by flattening the system load and reducing the peak. A function was developed to relate the level of load modification to the level of solar + battery installations.

Relevance: The load forecast that is incorporated into the power plan attempts to capture the factors that might impact the long-term system load. Though

behind-the- meter solar + battery systems have not yet been installed at a meaningful level, that might change over the next twenty years. The potential effect that a more significant buildout of these systems needs to be reflected in the long-term load forecast.

- Workplan: ANLYS 2 improve the long-term load forecast for emerging markets
- Background: The economics of installing behind-the-meter solar + battery systems are improving. The material and installation costs for PV systems have been declining for years. Now, battery costs (such as Lithium-Ion) are also on the decline. Several manufacturers offer battery systems that can be paired with PV systems, including Tesla, LG Chem and Sonnen. Utilities, like Tucson Electric Power, have begun to explore how these systems could be used to reduce peak demands and otherwise benefit the grid.











































Load Category	Load (MW, *aMW)	Hour of Day	
Peak Load - In	20,653	8 - 9 am	
Peak Load - Out (after S+B)	19,174	9 - 10 pm	
Peak Load Delta	(-) 1,479		
Avg Load In	18,441*		
Avg Load Out	17,883*		
Avg Load Delta	(-) 558*		
Min Load In	14,863	2 - 3 am	
Min Load Out	15,468	12 - 1 am	
Min Load Delta	(+) 604		















